



ADDENDUM TO THE RFQ DOCUMENTS		Page Number One (1)	Number of Pages Four (4)
Addendum No: ONE (1)		Date this Addendum Issued: January 11, 2019	
<u>Issuing Office:</u> Matanuska-Susitna Borough Purchasing Division 350 East Dahlia Avenue Palmer, Alaska 99645 Phone (907) 861-8601 Facsimile (907) 861-8617		<u>Previous Addenda Issued:</u> NONE Number Date of Issue _____ _____ _____	
<u>Return Acknowledgment To:</u> Issuing Office <u>Request for Quotations Title:</u> Supply & Install Metal Roof Snow Guards on Portables <u>Request for Quotations No:</u> 19-058Q		<u>Date and Hour RFQ Due:</u> Original: January 14, 2019 @ 2:00 PM Revised by Addenda No. <u>N/A</u> Revised to: <u>N/A</u>	
<p>The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the Request for Quotations (RFQ). In case of conflicts between this Addendum and previously issued Documents, this Addendum shall take precedence. Acknowledgement of this Addendum [XX] is / [] is not required. If required, please sign and date below and return this page with quotation.</p> <p><u>Question #1:</u> What type and length of fasteners are to be used? <u>Answer #1:</u> #9 x 1 1/2" zinc rubber washer roofing screws.</p> <p><u>Question #2:</u> Where are they to be placed? <u>Answer #2:</u> 2, (1 on each side), every 16".</p> <p><u>Answer #3:</u> Is sealant to be used? If so, where should it be placed? <u>Answer #3:</u> Yes, clear sealant at screw location between snow guard roof metal interfaces.</p> <p><u>Answer #4:</u> What type of snow guard do you want? <u>Answer #4:</u> Unpainted Galvalume 26 gauge. (See attached picture). <u>Delete requirement for snow guard to match roof color.</u></p> <p><u>Answer #5:</u> Do Davis Bacon Wages apply? <u>Answer #5:</u> No.</p> <p>Attachments (2): Snow guard picture – 1 page Portables pictures – 2 pages</p> <p style="text-align: center;">END OF ADDENDUM #1</p>			
Addendum Acknowledged By:			
Printed Name	Signed	Date	
Company Name: _____			
Requested by: 	Approved by: 	Date: 1/11/19	

