

ADDENDUM TO THE BID DOCUMENTS	Page Number: 1 of 1		
Addendum Number: 1	Date this Addendum Issued: 5/9/2019		
Issuing Office: Matanuska-Susitna Borough Purchasing Division 350 East Dahlia Avenue Palmer, Alaska 99645 Phone (907) 861-8601 Facsimile (907) 861-8617 purchasing@matsugov.us	Previous Addenda Issued: N/A <table border="0"> <tr> <td style="border-bottom: 1px solid black; width: 150px;">Number</td> <td style="border-bottom: 1px solid black;">Date of Issue</td> </tr> </table>	Number	Date of Issue
Number	Date of Issue		
Bid Number: 19-110B Bid Title: Houston High Portables Storage Electrical	Date and Hour of Bid Opening: As Advertised: 5/15/2019 @ 2:00 PM Revised by Addenda No.: NA Revised to: NA		
<p>The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the Contract Documents. In case of conflicts between this Addendum and previously issued Documents, this Addendum shall take precedence. <u>The Bidder must acknowledge receipt of this Addendum in the space provided on the Submittal Page.</u> Failure to do so may subject the Bidder to disqualification.</p> <p><u>CLARIFICATIONS RESULTING FROM BIDDER'S QUESTIONS:</u></p> <p>1. Q. Note F, per the general scope of work indicates electric power to (2) new portables. Construction of portables will not be complete before project is to be completed. What will be the plan for the conduit and wire at the new portable locations?</p> <p>A. The Scope of Work, section 1.01(F) STRIKE as written and REPLACE with the following:</p> <p>F. Provide conduit and the appropriate sized wires from existing meter base to New Portable location 110 and stub out and protect wires/conduit for connection to portable by other. Provide additional meter base and run conduit and appropriate sized wires to New Portable location 111, stub out, and protect wires/conduit for connection to portable by other. MEA connection to added meter base will be arranged by MSBSD. Coordination is required with MSBSD personnel for proper stub out locations, at new Portable locations, prior to performing the work.</p> <p style="text-align: center;">END OF ADDENDUM #1</p>			
Approved by: Signature on File			