

ADDENDUM TO BID DOCUMENT

ADDENDUM NUMBER: #1

DATE OF ISSUANCE: 1/31/2020

PAGE NUMBER: 1 of 2

BID NUMBER & TITLE: Tommy Moe Drive Electrical Upgrades

ISSUING OFFICE:



Purchasing Division
Matanuska-Susitna Borough
350 East Dahlia Avenue
Palmer, Alaska 99645
Phone: 907-861-8601
Facsimile: 907-861-8617
Email: purchasing@matsugov.us

PREVIOUS ADDENDUM ISSUED: NA

Addendum Number	Date of Issuance

DEADLINE FOR SUBMISSION OF QUESTIONS:

As Advertised: 1/30/2020 @ 5:00 PM
Revised by Addendum Number: NA
Revised to: NA

DATE AND HOUR OF BID OPENING:

As Advertised: 2/6/2020 @ 2:00 PM
Revised by Addendum Number: NA
Revised to: NA

The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the Contract Documents. In case of conflicts between this Addendum and previously issued Documents, this Addendum shall take precedence. **The bidder must acknowledge receipt of this Addendum in the space provided on the Submittal Page**, failure to do so may subject the bidder to **disqualification**.

CHANGES TO THE SCOPE OF WORK:

1. 1.01 General, Item G, Lower Level Mezzanine, **STRIKE** "1 - Exit sign with battery back up."

CLARIFICATIONS RESULTING FROM BIDDER'S QUESTIONS:

1. Q: Will there be a new Electrical panel to be installed, as the existing panel does not have enough spaces to accommodate the upgraded installations required?
A: MSB electrician confirmed there is enough spaces to accommodate additional circuits.
2. Q: If so what is the make and size of panel to be installed? Also can we use the existing 2" Conduit raceways already installed?
A: Existing empty conduits can be used for this work.
3. Q: Where would the new panel be located in the building?
A: No need for an additional panel.
4. Q: Which of the Exit signs/lights is to be replaced? E.G. North east door exit?
A: The exit signed is removed from the scope of work. Do not provide.
5. Q: Is the new 50amp RV receptacle on the west wall to be a dedicated circuit?
A: Yes. This new receptacle is to be similar to what is already installed on the east wall.
6. Q: Can the existing 50 amp RV receptacle be removed from the east wall?
A: No, this receptacle is to be left in use.
7. Q: What are the specifications for the ceiling mounted cord reels, the information provided in the RFP says "REELCRAFT 2XJCM" which is non-existent?
A: Please provide ceiling mounted cord reels with the following specifications; 120V, 20Amp, 50Ft length.
8. Q: Is the single pole light switch to be mounted next to the door on the front portion of the west wall?
A: The single pole light switch controlling the new mezzanine lights is to be located near the west personnel door under the mezzanine.

ADDENDUM CONTINUES ON THE NEXT PAGE

9. Q: Does the exposed conduit need to be painted?

A: No

PAGE NUMBER: 2 of 2

10. Q: Is Flex conduit or MC cable allowed for short whips to the light fixtures under the mezzanine? Or strictly conduit between all fixtures?

A: MC cable is not allowed. Flexible metal conduit can be used in lengths less than 6' to serve the light fixtures. Please refer to the 2009 MSB Facility Design Criteria Manual available at <https://www.matsugov.us/document>.

END OF ADDENDUM

APPROVED BY: Signature on File