

ADDENDUM TO BID DOCUMENT

ADDENDUM NUMBER: #2

DATE OF ISSUANCE: 2/12/2020

PAGE NUMBER: 1 of 3

BID NUMBER & TITLE: 20-089B Mark Drive Improvements

ISSUING OFFICE:



Purchasing Division
Matanuska-Susitna Borough
350 East Dahlia Avenue
Palmer, Alaska 99645
Phone: 907-861-8601
Facsimile: 907-861-8617
Email: purchasing@matsugov.us

PREVIOUS ADDENDUM ISSUED:

Addendum Number	Date of Issuance
#1	2/7/2020

DEADLINE FOR SUBMISSION OF QUESTIONS:

As Advertised: 1/31/2020 @ 5:00 PM
Revised by Addendum Number: NA
Revised to: NA

DATE AND HOUR OF BID OPENING:

As Advertised: 2/7/2020 @ 10:00 AM
Revised by Addendum Number: 2
Revised to: 2/18/2020 @ 2:00 PM

The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the Contract Documents. In case of conflicts between this Addendum and previously issued Documents, this Addendum shall take precedence. **The bidder must acknowledge receipt of this Addendum in the space provided on the Submittal Page**, failure to do so may subject the bidder to **disqualification**.

CHANGES TO THE BID DOCUMENT:

1. **STRIKE** revised Bid Opening date of 2/14/2020 @ 10:00 AM and **REPLACE** with Bid Opening date of 2/18/2020 @ 2:00 PM
2. **STRIKE** sheet B1, dated 10/2/2018, 1 page and **REPLACE** with sheet B1, dated 2/12/2020, 1 page. (see attachment for revised sheet)

CLARIFICATIONS RESULTING FROM BIDDER'S QUESTIONS:

1. Q: Where does the 12" select material, type B get placed as shown in the typical section?
A: B1 is revised to clarify that this material is to be used where benching is required per section 203 of the specifications. The cross sections show where the road is to be widened and are accurate.
2. Q: The cross sections for this project do not depict the "Select Material B Prism" as shown in B1.
A: B1 is revised. The cross sections show where the road is to be widened, and show the type B prism, and are accurate. Benching is required per section 203 of the specifications when placing embankment to widen the road and is paid for under unclassified excavation.
3. Q: Does the earthwork summary include excavation for "Select Material B Prism"?
A: Yes. The earthwork summary is accurate.
4. Q: Is it anticipated that all the Useable Exc is going into the "Select Material B Prism"?
A: All of the select material, type B is anticipated to be gained from the excavation.
5. Q: Should contractor expect additional Select Material B may need to be imported?
A: It is not anticipated.
6. Q: Why is there no Select Material B pay item?
A: All of the select material, type B is anticipated to be gained from the excavation and paid for under that item.

ADDENDUM CONTINUES ON THE NEXT PAGE


ADDENDUM ATTACHMENTS:

1. Sheet B1, dated 2/12/2020 1 page.

END OF ADDENDUM

APPROVED BY: Signature on File

Date Revised: 2/12/2020, 10:49 AM
 Layout Name: Typical Sections
 File Path and Name: U:\2047062000\drawing\sheet\1325330_Mark Drive Typical Sections_r1.dwg
 Designed By:
 Drawn By:
 Checked By:



- NOTES:**
1. SEEDING WILL INCLUDE MULCH MATERIAL CONSISTING OF VERDYOL BIOTIC EARTH BLACK WITH EARTHBOUND SCIENTIFIC SOIL STABILIZER. SEE SPECIFICATIONS.
 - * THE CROSS SLOPE IN THE CUL-DE-SAC VARIES. USE LAYOUT POINTS TABLE TO CONSTRUCT.
 - ** ALL EXCAVATED MATERIALS MEETING THE REQUIREMENTS OF SELECTED MATERIAL, TYPE B MUST BE USED TO CONSTRUCT PROJECT FILLS BEFORE IMPORTING BORROW, TYPE B. SEE SECTION 203 OF THE SPECIFICATIONS.

SLOPE EXCEPTION TABLE									
LEFT				STATION TO STATION	RIGHT				REMARKS
CUT	FILL	DITCH/SLOPE HINGE OFFSET	FORESLOPE		FORESLOPE	DITCH/SLOPE HINGE OFFSET	FILL	CUT	
1.4:1	2:1	4.0'	2:1	"M"13+42	2:1	2	2:1	1.5:1	DEPRESSED DITCH FOR CROSS CULVERT. TRANSITION FROM STD. DITCH 10' BACK AND AHEAD ON LINE.
1.4:1	2:1	4.0'	2:1	"M"22+25	2:1	2	2:1	1.5:1	DEPRESSED DITCH FOR CROSS CULVERT. TRANSITION FROM STD. DITCH 10' BACK AND AHEAD ON LINE.



SMK	2/12/20	UPDATED TYPICAL SECTION
BY	DATE	REVISION

Stantec
 PLANS DEVELOPED BY:
 STANTEC CONSULTING SERVICES INC.
 351 W. Parks Hwy., Suite 200
 Wasilla, Alaska 99654
 Phone: (907) 376-7815
 C.A. #126386

MARK DR. IMPROVEMENTS
 MATANUSKA-SUSITNA BOROUGH
TYPICAL SECTION

DATE: 2/12/2020
 SHEET: B1 of B1
 PROJECT NUMBER:
 18-09-1810